



INSTALLATION INSTRUCTIONS

- EXCAVATE TANK HOLE WITH VERTICAL WALLS TO 1 FOOT LARGER THAN TANK ON ALL SIDES.
- IF BOTTOM OF HOLE IS STONY, INSTALL 3" OF COMPACT SAND & LEVEL OUT WITH SCREED.
- INSTALL TANK IN CENTER OF HOLE, KEEPING 1 FOOT VOID SPACE ON ALL SIDES
- AS TANK IS FILLING WITH WATER, FILL IN VOID SPACE WITH COMPACT GRANULAR (SANDY) SOIL FREE OF LARGE CLUMPS OF CLAY. TANK MUST BE BACKFILLED BEFORE USE.
- INSTALL REST OF SYSTEM, & AFFIX RISERS TO TANK /ADAPTORS WITH WATERPROOF ADHESIVE.
- PERFORM WATERTIGHTNESS TEST IN FIELD AS REQUIRED BY LOCAL JURISDICTION.
- UPON APPROVAL, CAREFULLY BACKFILL WITH NATIVE SOILS OVER TOP OF TANK.
- FINAL GRADE THE SURFACE TO AVOID CHANNELLING SURFACE WATER TO TANK.
- OUR DRIVER CANNOT ENTER ANY EXCAVATION.
- ALL MEASUREMENTS ARE APPROXIMATE.
- ALL TANK SEALS AND GASKETS SHALL MEET A.S.T.M. C1644 AS PER MANUFACTURER.

NOT TO SCALE

WHITE BLOCK CO., INC.
 CONCRETE · PUMICE · BUILDING PRODUCTS
 QUALITY MANUFACTURER SINCE 1947
 WWW.WHITEBLOCKCOMPANY.COM

6219 East Trent Spokane, Washington 99212-1280 509/534-0651 FAX 509/534-0654

**1,000 GALLON
 DOUBLE COMP.
 SEPTIC TANK** / **500 GALLON
 PUMP CHAMBER**

SHEET

S-5

REVISED
 12/15/11