


NON TRAFFIC SIZE PRODUCT
1,500 GALLON # 5010

*TRAFFIC RATED SIZE PRODUCT
1,500 GALLON # 5011

1,500 GALLON
*HEIGHT 68"
LENGTH 126"
WIDTH 74"
INLET 55"
OUTLET 52"

* FOR TRAFFIC TOP ADD 4"
TO TOTAL HEIGHT. ADDITIONAL
REINFORCING IN TOP OF NO.
4 REBAR 6" O.C. EA. WA.



INSTALLATION INSTRUCTIONS

1. EXCAVATE TANK HOLE WITH VERTICAL WALLS TO 1 FOOT LARGER THAN TANK ON ALL SIDES.
2. IF BOTTOM OF HOLE IS STONY, INSTALL 3" OF COMPACT SAND & LEVEL OUT WITH SCREED.
3. INSTALL TANK IN CENTER OF HOLE, KEEPING 1 FOOT VOID SPACE ON ALL SIDES
4. AS TANK IS FILLING WITH WATER, FILL IN VOID SPACE WITH COMPACT GRANULAR (SANDY) SOIL FREE OF LARGE CLUMPS OF CLAY. TANK MUST BE BACKFILLED BEFORE USE.
5. INSTALL REST OF SYSTEM, & AFFIX RISERS TO TANK /ADAPTORS WITH WATERPROOF ADHESIVE.
6. PERFORM WATERTIGHTNESS TEST IN FIELD AS REQUIRED BY LOCAL JURISDICTION.
7. UPON APPROVAL, CAREFULLY BACKFILL WITH NATIVE SOILS OVER TOP OF TANK.
8. FINAL GRADE THE SURFACE TO AVOID CHANNELLING SURFACE WATER TO TANK.
9. OUR DRIVER CANNOT ENTER ANY EXCAVATION.
10. ALL MEASUREMENTS ARE APPROXIMATE.
11. ALL TANK SEALS AND GASKETS SHALL MEET A.S.T.M. C1644 AS PER MANUFACTURER.

NOT TO SCALE