



ONE PIECE 1,000 GALLON SINGLE	
HEIGHT	66"
LENGTH	96
WIDTH	66
INLET	54"
OUTLET	52"

23.4 GALLONS
PER INCH

CAN BE SPECIAL ORDERED FOR
USE AS WATER STORAGE TANK
1,300 GALLONS #3011

PRODUCT #3006
3008 TRAFFIC LOADING

INSTALLATION INSTRUCTIONS

- EXCAVATE TANK HOLE WITH VERTICAL WALLS TO 1 FOOT LARGER THAN TANK ON ALL SIDES.
- IF BOTTOM OF HOLE IS STONY, INSTALL 3" OF COMPACT SAND & LEVEL OUT WITH SCREED.
- INSTALL TANK IN CENTER OF HOLE, KEEPING 1 FOOT VOID SPACE ON ALL SIDES
- AS TANK IS FILLING WITH WATER, FILL IN VOID SPACE WITH COMPACT GRANULAR (SANDY) SOIL FREE OF LARGE CLUMPS OF CLAY. TANK MUST BE BACKFILLED BEFORE USE.
- INSTALL REST OF SYSTEM, & AFFIX RISERS TO TANK /ADAPTORS WITH WATERPROOF ADHESIVE.
- PERFORM WATERTIGHTNESS TEST IN FIELD AS REQUIRED BY LOCAL JURISDICTION.
- UPON APPROVAL, CAREFULLY BACKFILL WITH NATIVE SOILS OVER TOP OF TANK.
- FINAL GRADE THE SURFACE TO AVOID CHANNELLING SURFACE WATER TO TANK.
- OUR DRIVER CANNOT ENTER ANY EXCAVATION.
- ALL MEASUREMENTS ARE APPROXIMATE.
- ALL TANK SEALS AND GASKETS SHALL MEET A.S.T.M. C1644 AS PER MANUFACTURER.

NOT TO SCALE

WHITE BLOCK CO., INC.
CONCRETE · PUMICE · BUILDING PRODUCTS
QUALITY MANUFACTURER SINCE 1947
WWW.WHITEBLOCKCOMPANY.COM
6219 East Trent Spokane, Washington 99212-1280 509/534-0651 FAX 509/534-0654

**1,000 GALLON ONE PIECE SINGLE
COMPARTMENT TANK**

SHEET

S-3

REVISED
12/15/11